



**HINDUSTAN PETROLEUM CORPORATION LTD.**  
(A Govt. of India Undertaking)  
**Quality Control Laboratory, Vashi Terminal**  
PLOT NO-99, TURBHE MIDC, NAVI MUMBAI-400705



Certificate No.: TC-5246

**LABORATORY TEST REPORT**

PRODUCT NAME : HSD / HSD BLEND  
SENDER'S NAME : ABHITECH ENERGYCON LTD  
DATE SAMPLE RECEIVED : 27.08.2021  
DATE OF REPORT : 27.08.2021  
SOURCE OF SAMPLE : N.A  
LABORATORY ID NO. : AS MENTIONED IN TABLE  
PARTICULARS OF SAMPLE: N.A  
CLIENT SAMPLE ID : AS MENTIONED IN TABLE  
SEAL NOS. : N.A

Sr. no	Particulars of sample/ Client ID	Lab ID	Test parameter	Test method	Results
1	DIESEL	MIS /ES /365	CETANE NO	ASTM 613	52.1
2	DIESEL +THERMOL D	MIS /ES /367	CETANE NO	ASTM 613	54.0

Remark: Samples record test results as above.

  
AUTHORISED SIGNATORY

प्रभाकर एस. सावंत  
Prabhakar S. Sawant  
अधिकारी गुणवत्ता नियंत्रण  
Quality Control Officer  
हिन्दुस्तान पेट्रोलियम कॉर्पोरेशन लि.  
Hindustan Petroleum Corporation Limited  
वाशी टर्मिनल  
Vashi Terminal

\*\*\* END OF TEST REPORT \*\*\*